Roof Repair Services IFB No. GC2018092545_005001_5503



DESCRIPTION: Furnish all required labor, materials and equipment necessary to provide Scope-of-Service at the described location. Work is being authorized by SynergyNDS as part of the TurnKey Recovery Program[™] in limited liability partnership with the Florida Municipal Insurance Trust (FMIT).

LOCATION: Calhoun County | New Courthouse | Roof Repair Services | 425 E. Central Ave, Blountstown, FL

SUBMITTAL INSTRUCTIONS: For purposes of generating bid - IFB Packet includes scope specifications and bid sheet specific to referenced project.

- Bids shall be received no later than 9/5/19 (emailed to bids@synergynds.com)
- Include Subject Line Reference: Roof Repair Services IFB No. GC2018092545_005001_5503
- Contractor is required to identify and validate all necessary task items, measurements/dimensions &/or other applicable conditions in support of described scope-of-work. Contractor's Bid is to account for all work to be performed in accordance to trade standards and as required by Ordinance & Law (whether or not a 3rd Party Professional has provided additional comment/support material).
- Bid shall be completed and submitted using **ONLY** the <u>Contractor Submittal Form</u> (provided at the end of the IFB Packet).
- Bid award will be made based on best overall LUMP SUM project value as determined by SynergyNDS in accordance to market valuation, project demands &/or critical path. Contributing factors, in addition to price, may be considered as necessary to help determine bid award based on any additional criteria set forth by the specific FMIT Insured Member.
- Bids received after above deadline or that are not submitted in accordance to Submittal Instructions may be rejected without further explanation or contractor notification.
- SynergyNDS reserves the right to modify this IFB at any time during the bid process. Timely notice to all bidders will be given.

Roof Repair Services IFB No. GC2018092545_005001_5503 RETURN BID TO:

SynergyNDS / Hurricane Michael Recovery

FMIT Turnkey Recovery Program Attention: <u>bids@synergynds.com</u> Request On-Site Project Visit by emailing <u>bids@synergynds.com</u>

Roof Repair Services IFB No. GC2018092545_005001_5503

SCOPE OF WORK: Scope includes labor, tools, equipment, PPE, materials, supervision, and insurance necessary to complete the work described in general below. All scope-of-work shall be completed in accordance to manufacture specifications, building codes and applicable industry standards. Work is to begin no later than 2 weeks from contract award notification. Work is to be completed within 30 days of start to project. Number of days does not include weather delays. All weather delays shall be communicated with SynergyNDS. Any concerns with timeline is to be discussed with onsite project manager and an email is to be sent to <u>hurricanemichael@synergynds.com</u> for contract documentation.

1. Roof Replacement

The Scope of Work included in this RFP includes replacing a standing seam metal roof at the Calhoun County Courthouse with a new like-kind roof that meets all required codes and standards in accordance with the Engineered Design and Drawings prepared by SCE Engineering. Scope of work includes but is not limited to:

- Remove dispose of existing roof and insulation:
- Replace standing seam metal roof in accordance with Engineered Design and Drawings;
- Provide and install 3" R-11 vinyl faced insulation;
- Provide and install rakes and ridge metal as required;
- Remove and reset roof top vents as required;
- Repair damaged fascia as required; and
- Remove and replace gutters and downspouts.
- Contractor is required to dry-in the roof each day to prevent water intrusion.
- Contractor is responsible for repairing any interior damaged caused to the facility by water or other as a result of roof repairs.
- Contractor must construct covered walkways in accordance with OSHA standards to protect pedestrians entering and exiting the facility.
- Contractor will be responsible for barricading areas.
- Protect all landscaping around the building. Contractor will be responsible for any damage.
- Daily cleanup of the job site will be required.

*Roof must be installed as per the design and specifications included in the Engineered Drawings and Design prepared by SCE Engineering.

1. Roof Framing and Anchoring

The current Roof Framing System requires modifications to meet current codes and standards. Modifications include adding vertical supports and anchors throughout. Roof Framing must be constructed in accordance with the Roof Framing Plan included in the Engineered Drawings and Design prepared by SCE Engineering. All costs associated with Roof Framing must be separately identified on the Bid Sheet supplied in this RFP.

Roof Repair Services IFB No. GC2018092545_005001_5503

Contractor is responsible for ensuring that the roof replacement is performed in accordance with the design and specifications included in the Engineered Drawings and Design.

ADDITIONAL REQUIREMENTS:

- Bid price to include all labor, materials, supplies, tools and other equipment as required to complete work.
- Contractor is responsible for offloading and staging material and equipment.
- Contractor is responsible for determining and verifying measurements, dimensions and quantities as necessary to complete the Scope of Work.
- All work to be completed in accordance to all national, state, and/or local laws, codes, ordinances, and/or policies.
- Contractor is responsible for obtaining, posting, and maintaining relevant permits to the work being performed.
- Contractor will be required to call in inspections for each required phase of work.
- Contractor will be required to provide all warranty documentation prior to final payment.

ATTACHMENTS:

1. New Courthouse Engineered Drawings and Design.

Roof Repair Services IFB No. GC2018092545_005001_5503

GENERAL TERMS & CONDITIONS (Not otherwise specified under SUBMITTALS)

- Contractor shall abide by all applicable federal, state, and local regulations including those mandated by Law & Ordinance (codes & standards).
- Contractor is to obtain their own permits. Permits can be obtained by contacting the Building Department or other administering entity. Permit Fees are reimbursable direct from SynergyNDS (in addition to contractor's Lump Sum Proposal) if incurred and with proper documentation.
- Contractor is required to call in for all required inspections from the Building Dept or other administering entity. Proper documentation and jobsite posting is required.
- Contractor is to abide by all applicable OSHA requirements and standards. Contractor shall require all employees to utilize proper PPE, including but not limited to: fall protection harnesses, hard hats, safety glasses, safety foot wear, and gloves.
- Contractor may be asked to provide Material Safety Data Sheets (MSDS) to the industrial hygienist of record (IHC, Corp.) for chemical-based products that will be used including, but not limited to, glues, cleaners, solvents, anti-microbial products, sanitizing agents, etc. The industrial hygienist of record retains the right to not allow the use of any of the products selected.
- Contractor shall be responsible for supplying any and all necessary equipment, tools and materials to complete the scope of work unless directed otherwise in the IFB. This includes but is not limited to: Rental Equipment, Dumpsters, Storage Containers, Jobsite Trailer, General Conditions, Associated Expenses, Overhead & Profit which are to be included in the IFB Contractor Lump Sum Proposal.
- Contractor shall keep the Project Site and the surrounding areas free from the accumulation of waste materials, debris, etc. caused by operations performed under this Scope of Work. Upon completion, the contractor shall remove from Project Site, and surrounding areas:
 - Any waste materials, debris, etc. caused by completing the outlined Scope of Work.
 - Any tools, cleaning equipment, machinery, surplus materials originally furnished by the contractor
- The contractor shall be responsible for field verifying all conditions prior to implementation of the scope of work outside of any additional 3rd Party Professional assessment.
- The contractor shall provide and implement a site-specific health and safety plan to include hazard communication and related OSHA.

Roof Repair Services IFB No. GC2018092545_005001_5503

- The contractor is responsible to ensure that any sub-contractors comply with the provisions and terms of this scope of work.
- The contractor is responsible for submitting applicable project and associated contract documents as defined by Architectural Drawings Specifications, Engineering Requirements, Certificates of Insurance, Change Order Requests and any written or documented deviations from approved scopes-of-work or Contract.
- If the contractor determines that deviations, modifications (change order or supplemental costs) from the initial scope-or-work are required, the Contractor shall submit a written request to SynergyNDS for review and approval prior to start of any additional work not otherwise included in initial BID. The written request will contain, at a minimum:
 - Reason for deviation or modification
 - Description of deviation or modification
 - o Estimated time required for deviation or modification
 - Project cost addition or subtraction for deviation or modification
- The contractor is NOT responsible for any conditions or activities the building owner or employees implemented prior to their arrival to the job site. This includes removal of contents, equipment or personnel from the affected areas to the non-affected areas of the building.
- During the cleaning work, pre-existing damage to the building, building system failures, etc. may be found. If this occurs, the contractor will identify, document and record these deficiencies for review and consideration. The item shall be described, the location of the item shall be noted, the date the item was discovered and why the item was discovered. The contractor shall notify the Project Manager of any additional discoveries.

PAYMENT: Project is managed by SynergyNDS, Inc., under the FMIT Turnkey Recovery Direct Repair Program. Payment will be made directly from the Turnkey Recovery Managed Direct Repair Program to the contractor(s) in accordance with described terms & conditions. Qualified contractors may be eligible for an upfront material deposit or progress payments as determined prior to BID AWARD. **Contractor must be registered in the MVP (Managed Vendor Program) whereby required contractor documents must be uploaded to the database. There is annual \$49.95 processing fee as part of the initial vetting and background check.**

PAYMENT TERMS: Payments will be made after inspection and approval of work by SynergyNDS, City Building Official &/or Insurance Adjuster. Accurate invoices and required project documentation must be submitted to SynergyNDS for project audit prior to payment. *Material Deposits &/or Advanced Payments require Contractor to complete online registration in the FMIT Managed Vendor Program (MVP). MVP has

Roof Repair Services IFB No. GC2018092545_005001_5503

an annual \$49.99 Registration Fee to be part of the Contractor Direct Repair Program. Material Deposits &/or Advanced Payments will require a 2% Invoice Payment Discount.

HOLD HARMLESS: To the fullest extent permitted by law, the Contractor/Vendor shall indemnify, defend, and hold harmless SynergyNDS, Inc & FMIT, their officers, agents, employees, elected, and appointed officials, Insurance Representatives and volunteers from and against any and all claims, losses or liability, including attorney's fees, arising from injury or death to persons or damage to property occasioned by any act, omission, or failure of the Contractor/Vendor and any of its officers, agents, employees, and volunteers in satisfying the terms required by this contract.

<u>RIGHT TO ACCEPT, REJECT AND WAIVE DEFECTS</u>: FMIT &/or Contracting Agent reserves the right to: reject all quotations; waive formalities, technical defects, and minor irregularities; accept the quotation (if any) deemed most advantageous to and in the best interests of Insured Members of FMIT. Award will be based on price, contractor's daily performance capabilities, experience in completing projects of similar size and complexity, ability to provide the specified services when required &/or in accordance to critical path scheduling.

DAMAGES: Contractor will be held liable for any damage caused to the building and ancillary structure, and/or injury to the occupants resulting from the execution of the work or from not exercising proper precautionary protective measures. Any cost of repair/replacement resulting from damages shall be at the contractor's expense.

WORK-SITE PRACTICES:

- Contractor's workers, as well as the various trade contractors entering or leaving the work area, will all attend a site-specific safety meeting as well as daily safety meetings prior the scheduled work day.
- Contractor's workers entering or leaving the work area will don or remove personal protective equipment and clothing in the staging area outside of each work area.
- Waste materials transported from the bag out unit must be moved in a fashion that prevents spreading contamination outside the work area.

WORKER PERSONAL PROTECTION EQUIPMENT: The National Institute for Occupational Safety and Health (NIOSH) provides the following interim guidelines and warnings to restoration workers.

• Steel toed leather boots should be worn. Tennis shoes or sneakers should *not* be worn because they will transfer contamination and will not prevent punctures, bites, or crush injuries.

Roof Repair Services IFB No. GC2018092545_005001_5503

- Goggles, safety glasses with side shields or full-face shields shall be used when performing
 restoration related activities that involve demolition, cutting or the use of ANY power tools.
 Sun/glare-protective lenses may be needed in some work settings. The use of goggles or
 protective eyewear should also be worn during the application of any cleaners, sanitizers or
 disinfectants.
- Soft hat or another protective head cover. Wear an American National Standards Institute (ANSI) rated hardhat if there is any danger of falling debris or electrical hazards.
- Hearing protection (when working in an environment with any noise that you must shout over to be heard).
- Comfortable, form fitting, light weight clothing including long pants and a long-sleeved shirt or coveralls. Additional PPE, respiratory protection, or clothing may be required when specific exposure hazards are identified or expected at the work site. In some instances, the protective ensemble components (garment, boots and gloves) may need to be impervious to contaminated flood or other site-specific chemical, physical, or biological hazards. In all instances, workers are advised to wash their hands with soap and clean water, especially before eating or drinking. Protect any cuts or abrasions with waterproof gloves and dressings. The use of insect repellant, sun block and lip balm may also be required for some work environments. Drink plenty of bottled water and take frequent rest breaks to avoid overexertion.

THERMAL STRESSES: HEAT: Workers are at serious risk for developing heat stress. Excessive exposure to hot environments can cause a variety of heat-related problems, including heat stroke, heat exhaustion, heat cramps, and fainting. To reduce the potential for heat stress, drink a glass of fluid every 15 to 20 minutes and wear loose- fitting clothing. Additionally, incorporate work-rest cycles into work routines and when possible distribute the workload evenly throughout the day.

****Temporary cooling to the work areas shall only be authorized by the owner's representative based on the actual need for the work being performed. Where the conditions allow for the operation of part or all of the ventilation systems serving the work area then the need for temporary cooling is NOT necessary. The work area should be maintained at conditions that meet OSHA requirements for health and safety.***

WORKING IN CONFINED SPACES: If you are required to work in a boiler, furnace, pipeline, pit, pumping station, septic tank, sewage digester, storage tank, utility vault, well, or similar enclosure, you should be aware of the hazards of working in confined spaces. A confined space has one or more of the following characteristics:

- limited openings for entry or exit;
- unfavorable natural ventilation; or

Roof Repair Services IFB No. GC2018092545_005001_5503

• Is not designed for continuous worker occupancy.

Toxic gases, a lack of oxygen, or explosive conditions may exist in the confined area, resulting in a potentially deadly atmosphere. Because many toxic gases and vapors cannot be seen or smelled, never trust your senses to determine if safe entry is possible. **Never** enter a confined space unless you have been properly trained, even

to rescue a fellow worker! If you need to enter a confined space and do not have the proper training and equipment, contact your local fire department for assistance.

CONTRACT IMPLEMENTATION: Contract will be awarded upon review of all bids and proposals received by SynergyNDS. Initiation of contract is engaged upon written bid award letter. At such time, Contractor signed Request for Service Pricing (RFP) will serve as Contract. Complete Contract engagement will occur upon SynergyNDS receipt of all required documentation including but not limited to:

- Bonding (Performance Bond &/or Payment Bond)
- Certificate of General Liability Insurance
- Certificate of Auto Insurance
- Certificate of Worker's Compensation or Letter of Exemption
- Contractor's W-9
- State Licenses

Further description of insurance requirements is listed in "Insurance & Licensing Requirements."

ASSIGNMENT OF CONTRACT: Contractor shall not assign the contract or any part thereof to any person, firm, corporation or company unless such assignment is approved in writing by the Purchasing Agent. Such acceptance shall be at the sole discretion of the SynergyNDS upon request of the Contractor. Upon approved and executed written authorization, Contractor will be responsible for coordination of work with other trades. Failure to coordinate this work shall not constitute additional cost as governed by the Lump Sum Contract Award.

ASSIGNMENT OF CONTRACTOR: Contractor is responsible for supplying all required Personal Protective Equipment (PPE), including but not limited to the furnishing and appropriate use of: hard hat(s), safety glasses, face shields, ear plugs, gloves, boots, fall protection (where required), breathing protection (where required), tie off ropes/apparatuses/points (where required), fire extinguishers, first aid kits, etc. Contractor is required to be familiar with and follow all OSHA and State of Florida's safety requirements.

Contractor is to hold daily jobsite safety meetings that review the work to be performed, the hazards involved and the methods for reducing and eliminating such hazards, as well as maintain meeting records, - including attendance lists, which shall be kept onsite and available for SynergyNDS review at all times. Contractor shall be solely liable for any and all OSHA violations associated with his/her employees.

Roof Repair Services IFB No. GC2018092545_005001_5503

SynergyNDS reserves the right to hold weekly progress meetings for which the Subcontractor shall attend. Contractor shall be responsible for daily cleanup of the work performed herein. Failure to cleanup daily after trade will result in cleanup supplementation at Contractor's cost. Twenty-Four (24) hour notice will be given prior to supplementation. Contractor shall be responsible for delivery, loading, unloading, storage, protection, etc. of all work provided herein.

ENERGY EFFICIENCY: The Contractor shall comply with all mandatory standards and policies relating to energy efficiency which are contained in the energy conservation plan issued in compliance with the Energy Policy and Conservation Act (Pub.L. 94-163) for the State in which the work under this contract is performed.

PROCUREMENT OF RECOVERED MATERIALS: (a) In accordance with Section 6002 of the Solid Waste Disposal Act, as amended by the Resource Conservation and Recovery Act, the Contractor shall procure items designated in guidelines of the Environmental Protection Agency (EPA) at 40 CFR Part 247 that contain the highest percentage of recovered materials practicable, consistent with maintaining a satisfactory level of competition. The Contractor should procure items designated in the EPA Guidelines that contain the highest percentage of recovered materials practical unless the Contractor determines that such items: (1) are not reasonably available in a reasonable period of time; (2) fail to meet reasonable performance standards, which shall be determined on the basis of the guidelines of the National Institute of Standards and Technology; (3) are only available at un price.

FAILURE TO COMPLY: For failure to deliver in accordance with specifications, SynergyNDS may cancel the contract or any part thereof and purchase services on the open market, charging any additional cost to the Contractor. Contractor shall comply with all applicable state, federal and local codes, and pay all permits, licenses and certificates, and other fees as required by the work.

INSURANCE & LICENSING REQUIREMENTS: Before starting work, the Contractor will provide SynergyNDS proof of Worker's Compensation and Commercial and Public Liability Insurance. The Contractor must be licensed to do business in the State of Florida and SynergyNDS must be named as an additional insured on general liability insurance certificate.

Contractor will need to go to <u>http://www.synergyfmit.com/</u> click managed programs tab, then click on managed vendor program and complete the initial registration for the Managed Vendor Program (MVP). Contractor will be required to upload the following information (when applicable) prior to contract award and eligible material deposits.

- The Contractor will carry Worker's Compensation Insurance for all employees engaged in work at the site, in accordance with State or Territorial Worker's Compensation Laws.
- Commercial and Public Liability with bodily injury and property damage limits will be at a combined single limit of at least \$500,000 to protect the contractor and each subcontractor against claims for injury to or death of one or more persons.

Roof Repair Services IFB No. GC2018092545_005001_5503

- Automobile Liability on owned and non-owned motor vehicles used on the site(s), or in connection with the sites, for a combined single limit for bodily injury and property damages of not less than \$500,000.00 per occurrence.
- Builder's Work Insurance limit of at least \$5,000.00 per occurrence and \$10,000.00 aggregate.
- Professional Liability \$1,000,000 per occurrence (if applicable).

Contractor will not allow insurance coverage to lapse and will provide Turnkey Recovery Project Manager with updated Certificates of Insurance as necessary. All policies must provide that at least thirty (30) days' notice of cancellation will be given to the FMIT Project Manager and the contractor.

The certificate holder(s) must be noted as:

Synergy NDS, Inc. 1400 Sarno Rd Melbourne, FL 32935

Additional MANAGED PROGRAM INFORMATION is available at <u>www.synergyfmit.com</u> in support of:

- FMIT TurnKey Recovery
- MVP (Managed Vendor Program)
- FastTrack (Contractor Upfront Payment & Load Program).

FEDERAL TERMS: Contracts issued by SynergyNDS to the Vendor are subject to federal terms in this document. By performing the work, Vendor has accepted these terms.

MAINTENANCE OF RECORDS

CONTRACTOR shall maintain all books, records, and documents directly pertinent to performance under this Agreement in accordance with generally accepted accounting principles consistently applied. Records shall be retained for a period of seven years from the termination of this agreement or for a period of five years from the submission of the final expenditure report as per 2 CFR §200.333, whichever is greater. Each party to this Agreement or its authorized representatives shall have reasonable and timely access to such records of each other party to this Agreement for public records purposes during the term of the Agreement and for four years following the termination of this Agreement. If an auditor employed by SynergyNDS or Clerk determines that monies paid to CONTRACTOR pursuant to this Agreement were spent for purposes not authorized by this Agreement, or were wrongfully retained by the CONTRACTOR, the CONTRACTOR shall repay the monies together with interest calculated pursuant to Sec. 55.03, of the Florida Statutes, running from the date the monies were paid by SynergyNDS.

TERMINATION

A. In the event that the CONTRACTOR shall be found to be negligent in any aspect of service, SynergyNDS shall have the right to terminate this agreement after five days written notification to the CONTRACTOR.

Roof Repair Services IFB No. GC2018092545_005001_5503

B. Either of the parties hereto may cancel this Agreement without cause by giving the other party sixty (60) days written notice of its intention to do so.

C. Termination for Cause and Remedies: In the event of breach of any contract terms, SynergyNDS retains the right to terminate this Agreement. SynergyNDS may also terminate this agreement for cause with CONTRACTOR should CONTRACTOR fail to perform the covenants herein contained at the time and in the manner herein provided. In the event of such termination, prior to termination, SynergyNDS shall provide CONTRACTOR with five (5) calendar days' notice and provide the CONTRACTOR with an opportunity to cure the breach that has occurred. If the breach is not cured, the Agreement will be terminated for cause. If SynergyNDS terminates this agreement with the CONTRACTOR, SYNERGYNDS shall pay CONTRACTOR the sum due the CONTRACTOR under this agreement prior to termination, unless the cost of completion to SynergyNDS exceeds the funds remaining in the contract; however, SynergyNDS reserves the right to assert and seek an offset for damages caused by the breach. The maximum amount due to CONTRACTOR shall not in any event exceed the spending cap in this Agreement. In addition, SynergyNDS reserves all rights available to recoup monies paid under this Agreement, including the right to sue for breach of contract.

D. Termination for Convenience: SynergyNDS may terminate this Agreement for convenience, at any time, upon one (1) weeks' notice to CONTRACTOR. If SynergyNDS terminates this agreement with the CONTRACTOR, SYNERGYNDS shall pay CONTRACTOR the sum due the CONTRACTOR under this agreement prior to termination, unless the cost of completion to SynergyNDS exceeds the funds remaining in the contract. The maximum amount due to CONTRACTOR shall not exceed the spending cap in this Agreement. In addition, SynergyNDS reserves all rights available to recoup monies paid under this Agreement, including the right to sue for breach of contract.

NONDISCRIMINATION/EQUAL EMPLOYMENT OPPORTUNITY

CONTRACTOR and SYNERGYNDS agree that there will be no discrimination against any person, and it is expressly understood that upon a determination by a court of competent jurisdiction that discrimination has occurred, this Agreement automatically terminates without any further action on the part of any party, effective the date of the court order. CONTRACTOR or SYNERGYNDS agrees to comply with all Federal and Florida statutes, and all local ordinances, as applicable, relating to nondiscrimination. These include but are not limited to: 1) Title VII of the Civil Rights Act of 1964 (PL 88-352) which prohibits discrimination on the basis of race, color or national origin; 2) Title IX of the Education Amendment of 1972, as amended (20 USC ss. 1681-1683, and 1685-1686), which prohibits discrimination on the basis of sex; 3) Section 504 of the Rehabilitation Act of 1973, as amended (20 USC s. 794), which prohibits discrimination on the basis of handicaps; 4) The Age Discrimination Act of 1975, as amended (42 USC ss. 6101-6107) which prohibits discrimination on the basis of age; 5) The Drug Abuse Office and Treatment Act of 1972 (PL 92-255), as amended, relating to nondiscrimination on the basis of drug abuse; 6) The Comprehensive Alcohol Abuse and Alcoholism Prevention, Treatment and Rehabilitation Act of 1970 (PL 91-616), as amended, relating to nondiscrimination on the basis of alcohol abuse or alcoholism; 7) The Public Health Service Act of 1912, ss.

Roof Repair Services IFB No. GC2018092545_005001_5503

523 and 527 (42 USC ss. 690dd-3 and 290ee-3), as amended, relating to confidentiality of alcohol and drug abuse patient records; 8) Title VIII of the Civil Rights Act of 1968 (42 USC s. 3601 et seq.), as amended, relating to nondiscrimination in the sale, rental or financing of housing; 9) The Americans with Disabilities Act of 1990 (42 USC s. 12101 Note), as may be amended from time to time, relating to nondiscrimination on the basis of disability; 10) Any other nondiscrimination provisions in any Federal or state statutes which may apply to the parties to, or the subject matter of, this Agreement.

To the extent required by Federal program legislation, including FEMA grant and cooperative agreement programs, During the performance of this Agreement, the CONTRACTOR, in accordance with *Equal Employment Opportunity* (30 Fed. Reg. 12319, 12935, 3 C.F.R. Part, 1964-1965 Comp., p. 339), as amended by Executive Order 11375, *Amending Executive Order 11246 Relating to Equal Employment Opportunity*, and implementing regulations at 41C.F.R. Part 60 (Office of Federal Contract Compliance Programs, Equal Employment Opportunity, Department of Labor). <u>See</u> 2 C.F.R. Part 200, Appendix II, ¶ C, agrees as follows:

1) The contractor will not discriminate against any employee or applicant for employment because of race, color, religion, sex, sexual orientation, gender identity, or national origin. The contractor will take affirmative action to ensure that applicants are employed, and that employees are treated during employment, without regard to their race, color, religion, sex, sexual orientation, gender identity, or national origin. Such action shall include, but not be limited to the following: Employment, upgrading, demotion, or transfer, recruitment or recruitment advertising; layoff or termination; rates of pay or other forms of compensation; and selection for training, including apprenticeship. The contractor agrees to post in conspicuous places, available to employees and applicants for employment, notices to be provided by the contracting officer setting forth the provisions of this nondiscrimination clause.

2) The contractor will, in all solicitations or advertisements for employees placed by or on behalf of the contractor, state that all qualified applicants will receive consideration for employment without regard to race, color, religion, sex, sexual orientation, gender identity, or national origin.3) The contractor will not discharge or in any other manner discriminate against any employee or applicant for employment because such employee or applicant has inquired about, discussed, or disclosed the compensation of the employee or applicant or another employee or applicant. This provision shall not apply to instances in which an employee who has access to the compensation information of other employees or applicants as a part of such employee's essential job functions discloses the compensation of such other employees or applicants to individuals who do not otherwise have access to such information, unless such disclosure is in response to a formal complaint or charge, in furtherance of an investigation, proceeding, hearing, or action, including an investigation conducted by the employer, or is consistent with the contractor's legal duty to furnish information.

4) The contractor will send to each labor union or representative of workers with which it has a collective bargaining agreement or other contract or understanding, a notice to be provided by the agency contracting

Roof Repair Services IFB No. GC2018092545_005001_5503

officer, advising the labor union or workers' representative of the contractor's commitments under section 202 of Executive Order 11246 of September 24, 1965, and shall post copies of the notice in conspicuous places available to employees and applicants for employment.

5) The contractor will comply with all provisions of Executive Order 11246 of September 24, 1965, and of the rules, regulations, and relevant orders of the Secretary of Labor.

6) The contractor will furnish all information and reports required by Executive Order 11246 of September 24, 1965, and by the rules, regulations, and orders of the Secretary of Labor, or pursuant thereto, and will permit access to his books, records, and accounts by the contracting agency and the Secretary of Labor for purposes of investigation to ascertain compliance with such rules, regulations, and orders.

7) In the event of the contractor's non-compliance with the nondiscrimination clauses of this contract or with any of such rules, regulations, or orders, this contract may be canceled, terminated or suspended in whole or in part and the contractor may be declared ineligible for further Government contracts in accordance with procedures authorized in Executive Order 11246 of September 24, 1965, and such other sanctions may be imposed and remedies invoked as provided in Executive Order 11246 of September 24, 1965, or by rule, regulation, or order of the Secretary of Labor, or as otherwise provided by law.

FEDERAL CONTRACT REQUIREMENTS

The CONTRACTOR and its subcontractors must follow the provisions, as applicable, as set forth in 2 C.F.R. §200.326 Contract provisions and Appendix II to 2 C.F.R. Part 200, as amended, including but not limited to:

9.29.1 Davis-Bacon Act, as amended (40 U.S.C. §§3141-3148). When required by Federal program legislation, which includes emergency Management Preparedness Grant Program, Homeland Security Grant Program, Nonprofit Security Grant Program, Tribal Homeland Security Grant Program, Port Security Grant Program and Transit Security Grant Program, all prime construction contracts in excess of \$2,000 awarded by non-Federal entities must comply with the Davis-Bacon Act (40 U.S.C. §§3141-3144, and §§3146-3148) as supplemented by Department of Labor regulations (29 CFR Part 5, "Labor Standards Provisions Applicable to Contracts Covering Federally Financed and Assisted Construction"). In accordance with the statute, contractors must be required to pay wages to laborers and mechanics at a rate not less than the prevailing wages specified in a wage determination made by the Secretary of Labor. In addition, contractors must be required to pay wages not less than once a week. If applicable, SynergyNDS must place a current prevailing wage determination issued by the Department of Labor in each solicitation. The decision to award a contract or subcontract must be conditioned upon the acceptance of the wage determination. SynergyNDS must report all suspected or reported violations to the Federal awarding agency. When required by Federal program legislation, which includes emergency Management Preparedness Grant Program, Homeland Security Grant Program, Nonprofit Security Grant Program, Tribal Homeland Security Grant Program, Port

Roof Repair Services IFB No. GC2018092545_005001_5503

Security Grant Program and Transit Security Grant Program (it does not apply to other FEMA grant and cooperative agreement programs, including the Public Assistance Program), the contractors must also comply with the Copeland "Anti-Kickback" Act (40 U.S.C. § 3145), as supplemented by Department of Labor regulations (29 CFR Part 3, "Contractors and Subcontractors on Public Building or Public Work Financed in Whole or in Part by Loans or Grants from the United States"). As required by the Act, each contractor or subrecipient is prohibited from inducing, by any means, any person employed in the construction, completion, or repair of public work, to give up any part of the compensation to which he or she is otherwise entitled. SynergyNDS must report all suspected or reported violations to the Federal awarding agency. (1) Contractor. The contractor shall comply with 18 U.S.C. § 874, 40 U.S.C. § 3145, and the requirements of 29 C.F.R. pt. 3 as may be applicable, which are incorporated by reference into this contract.

(2) Subcontracts. The contractor or subcontractor shall insert in any subcontracts the clause above and such other clauses as the FEMA may by appropriate instructions require, and also a clause requiring the subcontractors to include these clauses in any lower tier subcontracts. The prime contractor shall be responsible for the compliance by any subcontractor or lower tier subcontractor with all of these contract clauses.

(3) Breach. A breach of the contract clauses above may be grounds for termination of the contract, and for debarment as a contractor and subcontractor as provided in 29 C.F.R. § 5.12.

9.29.2 <u>Contract Work Hours and Safety Standards Act</u> (40 U.S.C. 3701-3708). Where applicable, which includes all FEMA grant and cooperative agreement programs, all contracts awarded by SynergyNDS in excess of \$100,000 that involve the employment of mechanics or laborers must comply with 40 U.S.C.§§ 3702 and 3704, as supplemented by Department of Labor regulations (29 CFR Part 5). Under 40 U.S.C. §3702 of the Act, each contractor must compute the wages of every mechanic and laborer on the basis of a standard work week of 40 hours. Work in excess of the standard work week is permissible provided that the worker is compensated at a rate of not less than one and a half times the basic rate of pay for all hours worked in excess of 40 hours in the work week. The requirements of 40 U.S.C. 3704 are applicable to construction work and provide that no laborer or mechanic must be required to work in surroundings or under working conditions which are unsanitary, hazardous or dangerous. These requirements do not apply to the purchases of supplies or materials or articles ordinarily available on the open market, or contracts for transportation or transmission of intelligence.</u>

9.29.3 <u>Rights to Inventions Made Under a Contract or Agreement</u>. If the Federal award meets the definition of "funding agreement" under 37 CFR §401.2 (a) and the recipient or subrecipient wishes to enter into a contract with a small business firm or nonprofit organization regarding the substitution of parties, assignment or performance of experimental, developmental, or research work under that "funding agreement," the recipient or subrecipient must comply with the requirements of 37 CFR Part 401, "Rights to Inventions Made

Roof Repair Services IFB No. GC2018092545_005001_5503

by Nonprofit Organizations and Small Business Firms Under Government Grants, Contracts and Cooperative Agreements," and any implementing regulations issued by the awarding agency.

9.29.4 Clean Air Act (42 U.S.C. 7401-7671q.) and the Federal Water Pollution Control Act (33

<u>U.S.C. 1251-1387</u>). Contractor agrees to comply with all applicable standards, orders or regulations issued pursuant to the Clean Air Act (42 U.S.C. §§7401-7671q) and the Federal Water Pollution Control Act as amended (33 U.S.C. §§1251-1387) and will report violations to FEMA and the Regional Office of the Environmental Protection Agency (EPA). The Clean Air Act (42 U.S.C. 7401-7671q.) and the Federal Water PollutionControl Act (33 U.S.C. 1251-1387), as amended—applies to Contracts and subgrants of amounts in excess of \$150,000.

9.29.5 Debarment and Suspension (Executive Orders 12549 and 12689)—A contract award (see 2 CFR 180.220) must not be made to parties listed on the governmentwide exclusions in the System for Award Management (SAM), in accordance with the OMB guidelines at 2 CFR 180 that implement Executive Orders 12549 (3 CFR part 1986 Comp., p. 189) and 12689(3 CFR part 1989 Comp., p. 235), "Debarment and Suspension." SAM Exclusions contains the names of parties debarred, suspended, or otherwise excluded by agencies, as well as parties declared ineligible under statutory or regulatory authority other than Executive Order 12549.

9.29.6 Byrd Anti-Lobbying Amendment (31 U.S.C. 1352)—Contractors that apply or bid for an award exceeding \$100,000 must file the required certification. Each tier certifies to the tier above that it will not and has not used Federal appropriated funds to pay any person or organization for influencing or attempting to influence an officer or employee of any agency, a member of Congress, officer or employee of Congress in connection with obtaining any Federal contract, grant or any other award covered by 31 U.S.C. 1352. Each tier must also disclose any lobbying with non- Federal funds that takes place in connection with obtaining any Federal award. Such disclosures are forwarded from tier to tier up to the non-Federal award.

9.29.7 <u>Compliance with Procurement of recovered materials as set forth in 2 CFR § 200.322.</u> CONTRACTOR must comply with section 6002 of the Solid Waste disposal Act, as amended, by the Resource Conservation and Recovery Act. The requirements of Section 6002 include procuring only items designated in guidelines of the Environmental Protection Agency (EPA) at 40 CFR part 247 that contain the highest percentage of recovered materials practicable, consistent with maintaining a satisfactory level of competition, where the purchase price of the item exceeds \$10,000 or the value of the quantity acquired during the preceding fiscal year exceeded \$10,000; procuring solid waste management services in a manner that maximizes energy and resource recovery; and establishing an affirmative procurement program for procurement of recovered materials identified in the EPA guidelines.

Other Federal Requirements:

Roof Repair Services IFB No. GC2018092545_005001_5503

9.29.9 <u>Americans with Disabilities Act of 1990, as amended (ADA)</u> – The CONTRACTOR will comply with all the requirements as imposed by the ADA, the regulations of the Federal government issued thereunder, and the assurance by the CONTRACTOR pursuant thereto.

9.29.10 <u>Disadvantaged Business Enterprise (DBE) Policy and Obligation</u> - It is the policy of SynergyNDS that DBE's, as defined in 49 C.F.R. Part 26, as amended, shall have the opportunity to participate in the performance of contracts financed in whole or in part with SYNERGYNDS funds under this Agreement. The DBE requirements of applicable federal and state laws and regulations apply to this Agreement. SynergyNDS and its CONTRACTOR agree to ensure that DBE's have the opportunity to participate in the performance of this Agreement. In this regard, all recipients and contractors shall take all necessary and reasonable steps in accordance with 2 C.F.R. § 200.321(as set forth in detail below), applicable federal and state laws and regulations to ensure that the DBE's have the opportunity to compete for and perform contracts. SynergyNDS and the CONTRACTOR and subcontractors shall not discriminate on the basis of race, color, national origin or sex in the award and performance of contracts, entered pursuant to this Agreement. <u>2 C.F.R. § 200.321</u> <u>CONTRACTING WITH SMALL AND MINORITY BUSINESSES</u>, WOMEN'S BUSINESS ENTERPRISES, AND LABOR <u>SURPLUS AREA FIRMS</u>

a. If the CONTRACTOR, with the funds authorized by this Agreement, seeks to subcontract goods or services, then, in accordance with 2 C.F.R. §200.321, the CONTRACTOR shall take the following affirmative steps to assure that minority businesses, women's business enterprises, and labor surplus area firms are used whenever possible.

b. Affirmative steps must include:

(1) Placing qualified small and minority businesses and women's business enterprises on solicitation lists;

(2) Assuring that small and minority businesses, and women's business enterprises are

solicited whenever they are potential sources;

(3) Dividing total requirements, <u>when economically feasible</u>, into smaller tasks or quantities to permit maximum participation by small and minority businesses, and women's business enterprises;

(4) Establishing delivery schedules, where the requirement permits, which encourage participation by small and minority businesses, and women's business enterprises;

(5) Using the services and assistance, <u>as appropriate</u>, of such organizations as the Small Business Administration and the Minority Business Development Agency of the Department of Commerce.

(6) Requiring the Prime contractor, if subcontractor are to be let, to take the affirmative steps listed in paragraph (1) through (5) of this section.

9.30 The Contractor shall utilize the U.S. Department of Homeland Security's **E-Verify system** to verify the employment eligibility of all new employees hired by the Contractor during the term of the Contract and shall expressly require any subcontractors performing work or providing services pursuant to the Contract to likewise utilize the U.S. Department of Homeland Security's E-Verify system to verify the employment eligibility of all new employees hired by the subcontractor during the Contract term.

Roof Repair Services IFB No. GC2018092545_005001_5503

9.31 If attached, the CONTRACTOR is bound by the terms and conditions of the Federally-Funded Subaward and Grant Agreement between SYNERGYNDS and the Florida Division of Emergency Management (Division).

9.32 The CONTRACTOR shall hold the Division and SYNERGYNDS harmless against all claims of whatever nature arising out of the CONTRACTOR's performance of work under this Agreement, to the extent allowed and required by law.

Roof Repair Services IFB No. GC2018092545_005001_5503

This DOES NOT represent a commitment to buy. Any ACTUAL order resulting from this solicitation will be confirmed by Contract Engagement.

CONTRACTOR SUBMITTAL FORM

Company Name		
Address:		
City	State Zip	
Phone No	Email	
I, the undersigned, have read and preceding the attached Contractor	l understood all applicable Terms & Conditions as r Submittal Form.	described in the IFB Packet
Company Contact	Title	
Signature:	Date:	
LUMP SUM	PROPOSAL – SUBMITTAL DEADLIN	NE 09-05-19
Location #: 005001	L New Courthouse Roof Replacement	\$
Framing and Ancho	oring	\$
Total		\$
	quested Material Deposit	\$
	anced Payments require Contractor to complete online regist annual \$49.99 Registration Fee to be part of the Contractor I	

Deposits &/or Advanced Payments will require a 2% Invoice Payment Discount.


Roof Repair Services IFB No. GC2018092545_005001_5503

RETURN BID TO:

SynergyNDS / Hurricane Michael Recovery Email: bids@synergynds.com

Include Email Subject Line Reference: Roof Repair Services IFB No. GC2018092545_005001_5503

Attachment 1: New Courthouse Engineered Drawings and Design




	1.					·		·	
	67'-2 <u>4</u> "	1		-		-			
		-3'-1	1 <u>5</u> "			3'	-8"	2'	-6"
						Ŀ	•		
	L4x6x5/16 STEEL RAFTER (TYP.)	8'	8"			11	 -8" 	13	 3'-1"
			EXISTING 4" WEB ZEE BAR RAFTER w/ 3.5" TOP FLANGE AND 2.5" BOTTOM FLANGE (TYP.) TO BE REMOVED BY			¥	 	L	
		8'	3" CONTRACTOR						
			<u>-</u>	SUPPC	G L 2x2x1/4 STEEL VERTICAL ORT WELDED @ EACH END 0 L 4x6x5/16 STEEL RAFTER	7	'-0"	6'	'-7"
					IONS) TO BE REMOVED BY CONTRACTOR (TYP.)				+
		9'	9"			6	 '-7" 	7'	 -5"
11	5"		EXISTING L2x2x5/16 STEEL RAFTER (TYP.)			Ŀ	+		
					EXISTING L2x2x5/16 STEEL				†
				<u>+</u>	RAFTER (TYP.)	=	-2"		
	S3x5x1/4 STEEL HIP BEAM	9'	3"					10'	'-10"
нss 	3x5x1/4 STEEL HIP BEAM		<u> </u>				<u> </u>		
			11. 16 						
		-	T			F			-1"—
	THE REAL PROPERTY OF THE PROPE					8	 '-1"	7'	-7"
 /4 STE P BE		_12	-9"						
XXXXXXX						r	<u>+</u> •		+
	9'-7"					8	 -5"	8'	 -3"
				FXIST	ING 2" X 4" COLD ROLLED				
		6'-	10"	STEEL O.C. w SCRE	L VERTICAL SUPPORT @ 48" v/ (4) 1/4" X 3" SELF-TAPPING WS @ VERTICAL SUPPORT AFTER AND BEARING PLATE	r		•	+
		-		CONN RAFTE	ERTICAL SUPPORT IECTION (TYP. @ ZEE BAR ER LOCATIONS) TO BE IVED BY CONTRACTOR (TYP.)				
		7'.	7"			9'	'-2" 	11	 '-7"
							<u> </u>		
			EXISTING L 2x2x1/4 STEEL					•	+
		8'	VERTICAL SUPPORT WELDED — @ EACH END (TYP. @ L — 4x6x5/16 STEEL RAFTER 7" LOCATIONS) TO BE REMOVED BY CONTRACTOR (TYP.)			9	-3"		
							7" WEB ZEE BAR PURLINS w/ 3" FLANGE @ 48" O.C. (TYP. OF EVERYWHERE)	8'	'-4"
	F							I -	
		-4'	9"			5	'-3"	4'	 '-2"
		l	<u></u>	<u>я</u>			PRE-EXISTING CONC.		L
	►						PARAPET ROOF OUTLINE BELOW (TYP.)		
	67'-2 <u>1</u> "					►		-	

TRUSS PLAN NOTES:

1. OWNER/CONTRACTOR SHALL INSTALL PROPOSED HSS 2x2x1/4 COLUMN @ 54" O.C. TO SUPPORT EACH EXISTING L4x6x5/16 RAFTER. IN ADDITION, EXISTING 4" WEB ZEE SHALL BE REMOVED & HSS 2x2x1/4 COLUMN SHALL BE INSTALLED BELOW TO SUPPORT 7" WEB PURLINS ABOVE, AS SHOWN. CONTRACTOR SHALL MATCH O.C. SPACING BETWEEN 7" WEB ZEE BAR PURLINS, NOT TO EXCEED 54" O.C. 2. THIS DESIGN IS INTENDED TO ADDRESS THE ROOF FRAMING MEMBERS, VERTICAL SUPPORTS, AND UPLIFT CONNECTIONS ONLY. ALL OTHER EXISTING STRUCTURAL COMPONENTS SUCH AS, BUT NOT LIMITED TO, THE PRE-EXISTING CONCRETE ROOF SYSTEM AND METAL ROOFING MATERIAL CONNECTIONS TO FRAMING MEMBERS ARE OUTSIDE THE SCOPE OF THIS DESIGN.

1 EXISTING ROOF FRAMING PLAN S1 SCALE: ¹/₄" = 1'-0" FRAMING PLAN NOTES:

- 1. INDICATES LOCATION OF L4x6x5/16 OR L2x2x5/16 STEEL STRUCTURAL MEMBER AS INDICATED PER EXISTING ROOF
- FRAMING PLAN. 2. XXXXXX - INDICATES LOCATION EXISTING 4" WEB ZEE BAR RAFTER w/
- 3.5" TOP FLANGE AND 2.5" BOTTOM FLANGE (TO BE REMOVED BE CONTRACTOR).
- 3. ______ INDICATES LOCATION OF HSS3x5x1/4 STEEL STRUCTURAL MEMBER.




NOTES: 1. CONTRACTOR TO VERIFY ALL DIMENSIONS PRIOR TO CONSTRUCTION. 2. ALL FLASHING & WEATHERPROOFING BY CONTRACTOR. 3. ALL FRAMING MEMBERS SHOWING SIGNS OF DEGRADATION SHALL BE REMOVED AND REPLACED. 4. DUE TO THE NATURE OF THIS PROJECT, UNFORESEEN STRUCTURAL PROBLEMS MAY ARISE DURING CONSTRUCTION. SCE SHALL BE NOTIFIED OF SUCH

DISCOVERIES PRIOR TO COMMENCING ANY FURTHER WORK. 5. FINAL ARCHITECTURAL PLANS WERE NOT AVAILABLE AT THE TIME OF THIS DESIGN. E.O.R. SHALL BE NOTIFIED OF ANY DISCREPANCIES PRIOR TO

CONSTRUCTION. 6. ALL TEMPORARY BRACING & SHORING SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR.

T١		R.	МА	OR L E	IDA NG	0 1 2 465 0 1 2 465 0 2 1 2 2 465 0 2 9 - 3860 0 1 4 2000	2
				BLOUNTSTOWN COURTHOUSE	20859 CENTRAL AVENUE	BLOUNTSTOWN, FLORIDA 32424	
PROJECT NUMBER: 19-691-03 REVISIONS:	DESIGNED BY: DRAWN BY: CHECKED BY: DATE BY ITEM	I B.BAUMGARDNER B.BAUMGARDNER J.HUSBAND	D FOR: CALHOUN COUNTY BOARD OF	COUNTY COMMISSION			



SCALE: ¹/₄" = 1'-0" FRAMING PLAN NOTES: 1. REFER TO SHEET S1 FOR EXISTING ROOF

ROOF FRAMING LEGEND HSS 2x2x1/4 COLUMN INSTALLED @ L 4x6x5/16 RAFTER (OR) HSS 3x5x1/4 RIDGE BEAM PER DETAIL 1-S2, INSTALL ADDITIONAL COLUMN 6" (MAX.) FROM EDGE OF EXISTING CONCRETE PARAPET WALL HSS224P HSS 2x2x1/4 COLUMN INSTALLED @ 7" WEB/3" FLANGE ZEE PURLIN LOCATIONS PER DETAIL 2-S2

TRUSS PLAN NOTES:

1. OWNER/CONTRACTOR SHALL INSTALL PROPOSED HSS 2x2x1/4 COLUMN @ 54" O.C. TO SUPPORT EACH EXISTING L4x6x5/16 RAFTER. IN ADDITION, EXISTING 4" WEB ZEE SHALL BE REMOVED & HSS 2x2x1/4 COLUMN SHALL BE INSTALLED BELOW TO SUPPORT 7" WEB PURLINS ABOVE, AS SHOWN. CONTRACTOR SHALL MATCH O.C. SPACING BETWEEN 7" WEB ZEE BAR PURLINS, NOT TO EXCEED 54" O.C. 2. THIS DESIGN IS INTENDED TO ADDRESS THE ROOF FRAMING MEMBERS, VERTICAL SUPPORTS, AND UPLIFT CONNECTIONS ONLY. ALL OTHER EXISTING STRUCTURAL COMPONENTS SUCH AS, BUT NOT LIMITED TO, THE PRE-EXISTING CONCRETE ROOF SYSTEM AND METAL ROOFING MATERIAL CONNECTIONS TO FRAMING MEMBERS ARE OUTSIDE THE SCOPE OF THIS DESIGN.


PROPOSED ROOF FRAMING PLAN


FRAMING MEMBER SIZES AND LOCATIONS

NOTES: 1. CONTRACTOR TO VERIFY ALL DIMENSIONS PRIOR TO CONSTRUCTION. 2. ALL FLASHING & WEATHERPROOFING BY CONTRACTOR.

3. ALL FRAMING MEMBERS SHOWING SIGNS OF DEGRADATION SHALL BE REMOVED AND REPLACED.

- 4. DUE TO THE NATURE OF THIS PROJECT, UNFORESEEN STRUCTURAL PROBLEMS MAY ARISE DURING CONSTRUCTION. SCE SHALL BE NOTIFIED OF SUCH DISCOVERIES PRIOR TO COMMENCING ANY FURTHER WORK.
- 5. FINAL ARCHITECTURAL PLANS WERE NOT AVAILABLE AT THE TIME OF THIS DESIGN. E.O.R. SHALL BE NOTIFIED OF ANY DISCREPANCIES PRIOR TO CONSTRUCTION.
- 6. ALL TEMPORARY BRACING & SHORING SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR.





		Π	ע ע צ	Z Z		105	
			SOUTHEASTERN	CONSULTING ENGINEERS. INC.	P.O. 80X 141	WEWAHITCHKA, FL 32465 (850) 639-3860	LB# 29064
			0				
PRO TY LICE					IDA Engi Bh, I R 86		
ŀ							
	NG LAY				ЧПЕ	32424	
					9 CENTRAL AVENUE	FLORIDA	
					359 CENT	TSTOWN,	
C					20859	BLOUN	
	רעניינייניינייניינייניינייניינייניינייניי						
 0 7	ITEM						
REVISIONS:	DATE BY						
ю 	СНЕСКЕР ВУ:	J.HUSBAND	RD OF		EAST 37474		
	DRAWN BY:	BAUMGARDNER	OUNTY BOARC				
рколест NUMBER: 19-69	DESIGNED BY:	B.BAUMGARDNER B.BAUMGARDNER	R:CALHOUN C	COUNTY CO	7 20859 CENTRAL AVENUE 1 81 011NTGTOWN		
	Δ ΤΕ		EET	/E Z	3/1 ND.	9	

<u>GENERAL</u>

- 1. THE OWNER/CONTRACTOR SHALL VERIFY AND BE RESPONSIBLE FOR ALL F 2. THE CONTRACTOR SHALL COORDINATE ARCHITECTURAL, MECHANICAL, ELE DOCUMENTS WITH THE STRUCTURAL CONTRACT DOCUMENTS. NOTIFICATIO ANY CONFLICT AND/OR OMISSIONS.
- 3. FOR DIMENSIONS NOT SHOWN ON THE STRUCTURAL CONTRACT DOCUMENT 4. THE CONTRACTOR SHALL VERIFY EXISTING SITE CONDITIONS, DIMENSIONS THE ENGINEER SHALL BE NOTIFIED IN WRITING OF ANY DISCREPANCIES IN I ELEVATIONS TO THOSE SHOWN IN THE STRUCTURAL CONTRACT DOCUMEN
- 5. THE REVIEW OF SUBMITTALS AND/OR SHOP DRAWINGS BY THE ENGINEER D SOLE RESPONSIBILITY TO REVIEW AND CHECK SHOP DRAWINGS PRIOR TO S CONTRACTOR REMAINS SOLELY RESPONSIBLE FOR ERRORS AND OMISSIO SHOP DRAWINGS AS THEY PERTAIN TO MEMBER SIZES, DETAILS, AND DIME DOCUMENTS. THE CONTRACTOR ALSO SHALL BE RESPONSIBLE FOR MEAN PROCEDURES OF CONSTRUCTION INCLUDING BUT NOT LIMITED TO DEMOLI
- 6. THE CONTRACTOR IS SOLELY RESPONSIBLE FOR THE DESIGN, CONSTRUCT BRACING, SHORING, TEMPORARY SUPPORTS, ETC. REQUIRED FOR STABILIT INTERMEDIATE STAGES OF CONSTRUCTION AND/OR DEMOLITION. 7. IN NO CASE SHALL STRUCTURAL ALTERATIONS OR WORK AFFECTING A STR
- APPROVED BY THE ENGINEER OF RECORD IN WRITING. 8. NO PROVISION OF ANY REFERENCED STANDARD SPECIFICATION, MANUAL INCORPORATED BY REFERENCE IN THE CONTRACT DOCUMENTS) SHALL BE RESPONSIBILITIES OF OWNER, CONTRACTOR, ENGINEER, SUPPLIER, OR AN EMPLOYEES FROM THOSE SET FORTH IN THE CONTRACT DOCUMENTS. NOF STRUCTURAL ENGINEER OF RECORD OR ANY OF THE STRUCTURAL ENGINE EMPLOYEES ANY DUTY OR AUTHORITY TO SUPERVISE OR DIRECT THE FURN ANY DUTY OR AUTHORITY TO UNDERTAKE RESPONSIBILITIES CONTRARY TO DOCUMENTS.
- 9. CONTRACT DOCUMENTS INCLUDE, BUT ARE NOT LIMITED TO, THE STRUCTUR SPECIFICATIONS), BUT DO NOT INCLUDE SHOP DRAWINGS, VENDOR DRAWIN BY THE CONTRACTOR.
- REFERENCE TO STANDARD SPECIFICATIONS OF ANY TECHNICAL SOCIETY. OF LOCAL OR STATE AUTHORITIES, SHALL MEAN THE LATEST STANDARD, C SPECIFICATION ADOPTED AT THE DATE OF TAKING BIDS, UNLESS SPECIFICA 11. CONTRACT DOCUMENTS SHALL GOVERN IN THE EVENT OF A CONFLICT WITH
- OF ACI, PCI, AISC, SJI OR OTHER STANDARDS. WHERE A CONFLICT OCCURS STRICTEST REQUIREMENT SHALL GOVERN. 12. MATERIAL, WORKMANSHIP, AND DESIGN SHALL CONFORM TO THE REFEREN
- 13. CONTRACTOR SHALL OBTAIN AND COORDINATE EDGE OF SLAB DIMENSION DEPRESSED SLAB LOCATIONS AND EXTENTS, SLAB SLOPES, CURB LOCATIO ARCHITECT/STRUCTURAL ENGINEER SHALL BE NOTIFIED OF ANY DISCREPA 14. CONTRACTOR HAS SOLE RESPONSIBILITY FOR MEANS, METHODS, SAFETY,
- OF CONSTRUCTION. 15. CONTRACTOR HAS SOLE RESPONSIBILITY TO COMPLY WITH ALL OSHA REG
- 16. REPRODUCTION OF STRUCTURAL DRAWINGS FOR SHOP DRAWINGS IS NOT NOT BE PROVIDED TO THE CONTRACTOR. 17. SUBMIT SHOP DRAWINGS WHICH ADEQUATELY DEPICT THE STRUCTURAL E
- CONTRACT DOCUMENTS. SHOP DRAWINGS SHALL BE SEALED BY ENGINEER SHOP DRAWINGS SHALL BE FOR CONFORMANCE WITH THE CONTRACT DOC SIZES OF MEMBERS AND THE CONTRACTOR'S INTERPRETATION OF THE DES DETAILS. REVIEW OF SUBMITTALS OR SHOP DRAWINGS BY THE ARCHITECT/ THE CONTRACTOR OF THE SOLE RESPONSIBILITY TO REVIEW AND CHECK A SUBMITTING TO THE STRUCTURAL ENGINEER. REVIEW OF SUBMITTALS OR S ARCHITECT/STRUCTURAL ENGINEER DOES NOT RELIEVE THE CONTRACTOR WITH THE CONTRACT DOCUMENTS. CONTRACTOR REMAINS SOLELY RESPO ASSOCIATED WITH THE PREPARATION OF SHOP DRAWINGS AS THEY PERTA DIMENSIONS SPECIFIED IN THE CONTRACT DOCUMENTS. SHOP DRAWINGS PROJECT STATE.
- 18. WHERE A SECTION OR DETAIL IS SHOWN OR DETAILED FOR ONE CONDITION CONDITIONS. DETAILS LABELED "TYPICAL" ON THE STRUCTURAL DRAWINGS THE PROJECT THAT ARE THE SAME OR SIMILAR. THE CONTRACTOR SHALL (IN DETERMINING SIMILAR AND LIKE CONDITIONS.
- 19. ALL FLASHING AND WATERPROOFING BY CONTRACTOR. 20. ALL ADA REQUIREMENTS SHALL BE ADHERED (IF APPLICABLE) TO AND MAY
- ENTIRETY. 21. PLANS DO NOT INCLUDE ANY FIRE ESCAPE PLAN, FIRE SPRINKLER, OR FIRE
- OWNER/CONTRACTOR SHALL PROVIDE APPLICABLE FIRE PROTECTION DESI SFT
- 22. OWNER/CONTRACTOR SHALL BE RESPONSIBLE FOR ALL THRESHOLD INSPE 23. ATTACH STAIR STRINGERS & LANDING FRAMING TO STAIRWELL STUD FRAM 24. INSTALL LATERAL BRACING AT GABLE END TRUSS AS SPECIFIED BY TRUSS

CODE DESIGN

	LIVE LOAD	DE
ESTIMATED DEFLECTIONS (IN INCH	IES) ARE AS FOLLOWS:	
1. WIND LOADS: SEE TABLE		
		ESTIMATED DEFLECTIONS (IN INCHES) ARE AS FOLLOWS:

	LIVE LOAD	DEAD + LIVE LOAD
ROOF MEMBERS:	L/240 OR < 1"	L/180
FLOOR MEMBERS:	L/360 OR < ½"	L/240
WHERE, L = SPAN LENGTH (IN II THE LENGTH OF THE CANTILEV	,	NTERLINES OF SUPPORTS

FOUNDATION

1. FOUNDATION DESIGN IS BASED ON AN ASSUMED ALLOWABLE BEARING PRE IS NOT RESPONSIBLE FOR SUBSURFACE CONDITIONS ENCOUNTERED IN THE FOR DESIGN.

- 2. ALL FOUNDATION BEARING SOIL SHALL BE COMPACTED TO 98% STANDARD SPECIFIED BY AASHTO T-99 AND AASHTO T-180, RESPECTIVELY. 3. UNLESS OTHERWISE NOTED, ALL CONSTRUCTION JOINTS SHALL BE CONSTI SURFACES SHALL BE CLEANED BEFORE PLACEMENT OF ADJACENT CONCR BE INSTALLED AT 10' O.C. EACH WAY OR NO GREATER THAN 30 TIMES THE S SHALL BE A MINIMUM OF 1/8" WIDE AND TO A DEPTH OF 25% OF THE SLAB TH ALL CONCRETE SLABS LOCATED WITHIN VE FLOOD ZONES SHALL BE SCORE TO F.D.E.P. PERMIT DRAWINGS FOR ALL CONCRETE SLABS LOCATED SEAWA
- CONTROL LINE. 4. STRUCTURAL TESTING/INSPECTION AGENCY SHALL CERTIFY THE BEARING 5. NO FOOTINGS SHALL BE PLACED IN WATER.
- 6. ANY SOIL CONDITION ENCOUNTERED DURING EXCAVATION THAT IS CONTRA FOOTINGS AS OUTLINED IN THESE NOTES OR ON THE DRAWINGS SHALL BE ARCHITECT OR ENGINEER OF RECORD BEFORE PROCEEDING. 7. BACK FILL BOTH SIDES OF FOUNDATION WALLS AT SAME TIME TO PREVENT

CONCRETE MASONRY

- 1. CONCRETE MASONRY WORK SHALL CONFORM TO ACI 530, BUILDING CODE F AND ACI 530.1, SPECIFICATION FOR MASONRY STRUCTURES.
- 2. MINIMUM COMPRESSIVE STRENGTH OF CONCRETE MASONRY SHALL BE F'N 3. MORTAR SHALL COMPLY WITH THE BUILDING CODE REQUIREMENTS FOR CO
- FOLLOWING TYPE: TYPE M OR S WALLS BELOW GRADE
- 4. CONCRETE MASONRY UNITS SHALL BE GROUTED WITH 2,500 PSI COARSE G DOCUMENTS. GROUT SHALL CONFORM TO ASTM C476.
- 5. PROVIDE HORIZONTAL JOINT REINFORCEMENT WITH NO. 9 GAGE LONGITUD NOTED OTHERWISE. PROVIDE SPECIAL ACCESSORIES FOR CORNERS, INTER
- 6. MINIMUM VERTICAL WALL REINFORCEMENT SHALL BE #5 @32" UNLESS NOT 7. DEFECTIVE AREAS IN CONCRETE INCLUDING, BUT NOT LIMITED TO, HONEY-
- EXCEEDING 0.01 INCH SHALL BE REPAIRED. EXTENTS OF DEFECTIVE AREA TO BE DETERMINED BY THE STRUCTURAL ENGINEER.

8. REINFORCING DOWELS MUST BE TIED IN PLACE PRIOR TO POURING FOOTING. "WET-STICKING" IS NOT ALLOWED.

STRUCTURAL GENERAL NOTES


	SIRUCIURAL GEI	
INAL DIMENSIONS, PRIOR TO START.	REINFORCEMENT 1. REINFORCING STEEL SHALL CONFORM TO ASTM A615, GRADE 60, UNLESS NOTED OTHERWISE.	
ECTRICAL, PLUMBING, AND CIVIL WORKS ON SHALL BE MADE TO THE ENGINEER AND OF	2. WELDED WIRE FABRIC SHALL CONFORM TO ASTM A185 AND HAVE MINIMUM SIDE AND END LAPS OF 8".FOR ALL MONOLITHIC FOOTINGS, A DOUBLE LAYER OF WELDED WIRE FABRIC SHALL BE INSTALLED WITHIN 3'-0" OF ALL FOOTINGS (3" CLEAR OF OUTSIDE PERIMETER OF FOOTING)	 ALL HEADERS, BEAMS, POSTS, ETC. HAVE BEEN DESIGNED TO SUPPORT ROOF FRAMING MEMBERS AS SHOWN ON ROOF FRAMING PLAN. IT IS THE RESPONSIBILITY OF THE TRUSS MFG. TO NOTIFY E.O.R. OF ANY DISCREPANCY & PROVIDE FINAL TRUSS LAYOUT TO E.O.R. FOR STRUCTURAL PLAN REVISION IF LAYOUT VARIES FROM THAT SHOWN ON THIS PLAN SET.
S, AND ELEVATIONS PRIOR TO STARTING WORK. EXISTING SITE CONDITIONS, DIMENSIONS, OR	3. REINFORCING STEEL SHALL ONLY BE WELDED OR TACK-WELDED IF IT CONFORMS TO ASTM A706, AND AWS D1.4. REINFORCING SHALL NOT BE WELDED NOR TACK-WELDED UNLESS APPROVED BY THE STRUCTURAL ENGINEER OF RECORD.	 ALL DECK JOISTS HEREIN SHOWN AS 16" O.C. OR GREATER ARE INTENDED FOR 2 X 6 OR 5/4 X 6 WOOD DECKING. IT IS THE CONTRACTORS RESPONSIBILITY, IF USING COMPOSITE DECKING TO INSTALL DECK JOISTS @ 12" O.C. OR AS REQUIRED BY MANUFACTURERS SPECIFICATIONS. STRUCTURAL GLUED LAMINATED TIMBER SHALL BE PRODUCED IN ACCORDANCE WITH THE AMERICAN INSTITUTE
DOES NOT RELIEVE THE CONTRACTOR OF THE SUBMITTAL TO THE ENGINEER. THE	4. SUBMIT SHOP DRAWINGS WHICH ADEQUATELY DEPICT THE REINFORCING BAR SIZES AND PLACEMENT. WRITTEN DESCRIPTION OF REINFORCEMENT WITHOUT ADEQUATE SECTIONS, ELEVATIONS, AND DETAILS IS NOT ACCEPTABLE.	 OF TIMBER CONSTRUCTION (AITC). MINIMUM ALLOWABLE BENDING STRESS SHALL BE 2,400 PSI (DRY CONDITIONS). PROVIDE DRESSED SEASONED LUMBER, S4S, WITH A MAXIMUM MOISTURE CONTENT OF 19% AT TIME OF
INSIONS SPECIFIED IN THE CONTRACT IS, METHOD, TECHNIQUES, SEQUENCES, AND ITION PROCEDURES AND TEMPORARY SHORING.	 PROVIDE DOWELS FROM FOUNDATIONS THE SAME SIZE AND NUMBER AS THE VERTICAL WALL OR COLUMN REINFORCING, UNLESS NOTED OTHERWISE. REINFORCING DOWELS MUST BE TIED IN PLACE PRIOR TO POURING FOOTING. "WET-STICKING" IS <u>NOT</u> ALLOWED. 	DRESSING AS LISTED BELOW. 3.1. INTERIOR AND EXTERIOR LOAD-BEARING WALLS: SPRUCE PINE FUR (SPF) U.N.O.
TION, AND ERECTION OF SAFE AND ADEQUATE TY OF THE STRUCTURE DURING ALL	 PLACE REINFORCEMENT AS FOLLOWS, UNLESS NOTED OTHERWISE: 6.1. CAST-IN-PLACE (NON POST-TENSIONED) CONCRETE REINFORCEMENT COVER 	3.2. LINTELS, FLOOR JOISTS AND BEAMS: SOUTHERN PINE (S.P.), NO. 2 GRADE.
RUCTURAL MEMBER BE MADE, UNLESS	PERMANENTLY EXPOSED TO EARTH: CAST AGAINST THE EARTH 3" CLEAR EXPOSED TO EARTH OR WEATHER:	3.3. WOOD IN CONTACT WITH CONCRETE OR MASONRY SHALL BE FOUNDATION GRADE PRESSURE-TREATED. USE GALVANIZED NAILS IN PRESSURE-TREATED WOOD. THE PROTECTIVE COATING ON LIGHT GAUGE STEEL CONNECTIONS IN CONTACT w/ PRESSURE-TREATED WOOD SHALL BE IN ACCORDANCE WITH THE
OR CODE (WHETHER OR NOT SPECIFICALLY E EFFECTIVE TO CHANGE THE DUTIES AND IY OF THEIR CONSULTANTS, AGENTS, OR	FOR BARS LARGER THAN A NO. 5 BAR2" CLEARNO. 5 BARS OR SMALLER1 ½" CLEAR	CONNECTOR MANUFACTURERS RECOMMENDATIONS. 4. ENGINEERED LUMBER PRODUCTS
R SHALL IT BE EFFECTIVE TO ASSIGN TO THE EER OF RECORD'S CONSULTANTS, AGENTS, OR NISHING OR PERFORMANCE OF THE WORK OR	COLUMN TIES 1 ¾" CLEAR 6.2. MASONRY REINFORCING STEEL SHALL BE PLACED IN THE CENTER OF CMU CELLS, UNLESS NOTED OTHERWISE.	4.1. PARALLEL STRAND LUMBER (PSL) SHALL HAVE THE FOLLOWING MINIMUM ALLOWABLE STRESSES AND PROPERTIES: ALLOWABLE BENDING STRESS $F_B = 2900 \text{ PSI}$ COMPRESSION PERPENDICULAR TO GRAIN $F_{C^{\perp}} = 750 \text{ PSI}$
O THE PROVISIONS OF THE CONTRACT JRAL DOCUMENTS (DRAWINGS AND INGS, OR MATERIAL PREPARED AND SUBMITTED	7. REINFORCEMENT SHALL BE SPLICED ONLY AT LOCATIONS SHOWN OR NOTED IN THE STRUCTURAL DOCUMENTS, EXCEPT REINFORCEMENT MARKED "CONTINUOUS" CAN BE SPLICED AT LOCATIONS DETERMINED BY CONTRACTOR. SPLICES AT OTHER LOCATIONS SHALL BE APPROVED IN WRITING BY THE STRUCTURAL ENGINEER. REINFORCING STEEL SPLICES SHALL BE AS FOLLOWS, UNLESS NOTED OTHERWISE:	COMPRESSION PARALLEL TO GRAIN $F_{C } = 2900 \text{ PSI}$ HORIZONTAL SHEAR $F_V = 290 \text{ PSI}$ MODULUS OF ELASTICITY $E = 2,000,000 \text{ PSI}$ 4.2. LAMINATED VENEER LUMBER (LVL) SHALL HAVE THE FOLLOWING MINIMUM ALLOWABLE STRESSES AND
ORGANIZATION, OR ASSOCIATION OR TO CODES CODE, SPECIFICATION OR TENTATIVE ALLY STATED OTHERWISE.	MINIMUM LAP SPLICE LENGTH (IN.) - 3000 PSI CONCRETE No. 3 No. 4 No. 5 No. 6 No. 7 No. 8	PROPERTIES:ALLOWABLE BENDING STRESS $F_B = 2600 \text{ PSI}$ COMPRESSION PERPENDICULAR TO GRAIN $F_{C^{\perp}} = 750 \text{ PSI}$
TH THE CODE OF PRACTICE OR SPECIFICATIONS SWITHIN THE CONTRACT DOCUMENTS, THE	22 29 36 43 63 72 MINIMUM LAP SPLICE LENGTH (IN.) - 1500 PSI NORMAL WEIGHT CMU	COMPRESSION PARALLEL TO GRAIN $F_{c }$ = 2510 PSIHORIZONTAL SHEAR F_V = 285 PSIMODULUUS OF FLASTICITY F_v = 2000 000 DSI
NCED BUILDING CODE.	6-in CMU WALL 19 25 39 81 NA NA 8-in CMU WALL 19 25 31 57 79 113	MODULUS OF ELASTICITY E = 2,000,000 PSI 4.3. LAMINATED STRAND LUMBER (LSL) SHALL HAVE THE FOLLOWING MINIMUM ALLOWABLE STRESSES AND
IS, OPENING LOCATIONS AND DIMENSIONS, DNS, AND CMU WALL LOCATIONS. ANCY OR OMISSION.	8-in CMU WALL 19 25 31 57 79 113 12-in CMU WALL 19 25 31 53 61 75 RECOMMENCED END HOOKS ANCHORAGE LENGTH (IN.) - 3000 PSI CONCRETE	PROPERTIES:ALLOWABLE BENDING STRESS $F_B = 1700 \text{ PSI}$ COMPRESSION PERPENDICULAR TO GRAIN $F_{C^{\perp}} = 710 \text{ PSI}$ COMPRESSION PARALLEL TO GRAIN $F_{C } = 1835 \text{ PSI}$
TECHNIQUES, SEQUENCES, AND PROCEDURES	No. 3 No. 4 No. 5 No. 6 No. 7 No. 8	HORIZONTAL SHEAR F_V = 425 PSIMODULUS OF ELASTICITYE= 1,300,000 PSI
ULATIONS. PERMITTED. ELECTRONIC DRAWING FILES WILL	D2.253.003.754.505.256.00A or G6810121416	4.4. GLULAM BEAMS (GLU) SHALL HAVE THE FOLLOWING MINIMUM ALLOWABLE STRESSES AND PROPERTIES: ALLOWABLE BENDING STRESS $F_B = 3000 \text{ PSI}$ COMPRESSION PERPENDICULAR TO GRAIN $F_{C^{\perp}} = 805 \text{ PSI}$ TENSION PARALLEL TO GRAIN $F_{-11} = 1350 \text{ PSI}$
ELEMENTS AND CONNECTIONS SHOWN IN THE R LICENSED IN THE PROJECT STATE. REVIEW OF		HORIZONTAL SHEAR F_V = 300 PSIMODULUS OF ELASTICITYE= 2,100,000 PSI
CUMENTS REGARDING ARRANGEMENT AND SIGN LOADS AND CONTRACT DOCUMENT /STRUCTURAL ENGINEER DOES NOT RELIEVE	POST INSTALLED ANCHORS	4.5. PRESERVED GLULAM BEAMS (GLU) SHALL HAVE THE FOLLOWING MINIMUM ALLOWABLE STRESSES AND PROPERTIES: ALLOWABLE BENDING STRESS $F_B = 2400 \text{ PSI}$
ALL SUBMITTALS AND SHOP DRAWINGS BEFORE SHOP DRAWINGS BY THE R OF FULL RESPONSIBILITY FOR COMPLIANCE ONSIBLE FOR ERRORS AND OMISSIONS	 POST-INSTALLED ANCHORS SHALL ONLY BE USED WHERE SPECIFIED ON THE CONSTRUCTION DOCUMENTS. THE CONTRACTOR SHALL OBTAIN APPROVAL FROM THE ENGINEER-OF-RECORD PRIOR TO INSTALLING POST-INSTALLED ANCHORS IN PLACE OF MISSING OR MISPLACED CAST-IN-PLACE ANCHORS. CARE SHALL BE 	COMPRESSION PERPENDICULAR TO GRAIN $F_{C^{\perp}}$ = 740 PSIHORIZONTAL SHEAR F_{V} = 300 PSIMODULUS OF ELASTICITYE= 1,800,000 PS
AIN TO MEMBER SIZES, DETAILS, AND SHALL BE SEALED BY ENGINEER LICENSED IN	TAKEN IN PLACING POST-INSTALLED ANCHORS TO AVOID CONFLICTS WITH EXISTING REBAR. HOLES SHALL BE DRILLED AND CLEANED IN ACCORDANCE WITH THE MANUFACTURER'S WRITTEN INSTRUCTIONS. SUBSTITUTION REQUESTS FOR PRODUCTS OTHER THAN THOSE SPECIFIED BELOW SHALL BE SUBMITTED BY THE CONTRACTOR TO THE ENGINEER-OF-RECORD ALONG WITH CALCULATIONS THAT ARE PREPARED & SEALED BY A REGISTERED	 STRUCTURAL PANELS FLOOR PANELS SHALL BE CONSTRUCTED WITH TONGUE AND GROOVE APA RATED 3/4" PLYWOOD. FLOOR PANELS SHALL BE GLUED AND NAILED w/ 8d RING SHANK NAILS @4" O.C. AT PANEL EDGES AND AT 6" O.C. IN
N, IT SHALL APPLY TO ALL SIMILAR AND LIKE S APPLY TO ALL SITUATIONS OCCURRING ON CONSIDER ALL OF THE CONTRACT DOCUMENTS	PROFESSIONAL ENGINEER. THE CALCULATIONS SHALL DEMONSTRATE THAT THE SUBSTITUTED PRODUCT IS CAPABLE OF ACHIEVING THE PERTINENT EQUIVALENT PERFORMANCE VALUES (MINIMUM) OF THE SPECIFIED PRODUCT USING THE APPROPRIATE DESIGN PROCEDURE AND/OR STANDARD(S) AS REQ'D BY THE BUILDING CODE. PROVIDE CONTINUOUS SPECIAL INSPECTION FOR ALL MECHANICAL AND ADHESIVE ANCHORS PER THE	THE FIELD. 5.2. WALL PANELS SHALL BE CONSTRUCTED WITH APA RATED SHEATHING, SHEATHING SHALL BE ATTACHED WITH 8d COMMON NAILS @3" O.C. AT PANEL EDGES AND 6" O.C. IN THE FIELD. ALL PANEL EDGES SHALL BE BLOCKED.
NOT BE SHOWN ON THESE PLANS IN ITS	APPLICABLE EVALUATION REPORT. CONTACT MANUFACTURER'S REPRESENTATIVE FOR THE INITIAL TRAINING AND INSTALLATION OF ANCHORS AND FOR PRODUCT RELATED QUESTIONS AND AVAILABILITY. 1.1. CONCRETE ANCHORS	 5.3. ROOF PANELS SHALL BE CONSTRUCTED WITH APA RATED SHEATHING. SHEATHING SHALL BE ATTACHED WITH 8d RING SHANK NAILS @ 3" O.C. AT PANEL EDGES AND AT 6" O.C. IN THE FIELD. ALL PANEL EDGES SHALL BE BLOCKED OR ATTACHED WITH SIMPSON PSCA PANEL SHEATHING CLIPS. 5.4. NAIL HEADS SHALL NOT PENETRATE THE OUTER SURFACE OF SHEATHING.
E RELATED DESIGN ASPECTS, U.N.O SIGN/DOCUMENTS NOT SHOWN ON THIS PLAN	A. MECHANICAL ANCHORS SHALL HAVE BEEN TESTED AND QUALIFIED FOR USE IN ACCORDANCE WITH ACI 355.2 AND ICC-ES AC193 FOR CRACKED AND UNCRACKED CONCRETE RECOGNITION. PRE-APPROVED	6. FABRICATED WOOD TRUSSES
ECTION REQUIREMENTS (IF APPLICABLE).	MECHANICAL ANCHORS INCLUDE: - SIMPSON STRONG-TIE "TITEN-HD" (ICC-ES ESR-2713) - SIMPSON STRONG-TIE "STRONG-BOLT 2" (ICC-ES ESR-3037)	6.1. DESIGN OF WOOD TRUSSES SHALL BE THE SOLE RESPONSIBILITY OF THE CONTRACTOR. SUBMIT SHOP DRAWINGS, DESIGN LOAD DATA, AND SUPPORT REACTIONS SEALED BY AN ENGINEER LICENSED IN THE PROJECT STATE. REVIEW OF SHOP DRAWINGS SHALL BE FOR CONFORMANCE WITH THE CONTRACT
/ING w/ (2) SIMPSON SDWC15600 @ 16" O.C. MANUFACTURER.	B. ADHESIVE ANCHORS SHALL HAVE BEEN TESTED AND QUALIFIED FOR USE IN ACCORDANCE WITH ACI 355.4 AND ICC-ES AC308 FOR CRACKED AND UNCRACKED CONCRETE RECOGNITION. PRE-APPROVED ADHESIVE ANCHORS INCLUDE:	DOCUMENTS WITH REGARD TO TRUSS CONFIGURATION, AND THE CONTRACTOR'S INTERPRETATION OF DESIGN LOADS AND DETAILS. SUCH REVIEW SHALL NOT RELIEVE THE CONTRACTOR OF THE FULL RESPONSIBILITY FOR THE DESIGN OF THE TRUSSES OR TRUSS CONNECTIONS NOT SPECIFICALLY DETAILED
	- SIMPSON STRONG-TIE "SET-XP" (ICC-ES ESR-2508) - SIMPSON STRONG-TIE "AT-XP" (IAPMO-ES ER-0263) - HILTI HIT HY150 INJECTION ADHESIVE - EPCON CERAMIC 6 EPOXY ADHESIVE SUPPLIED BY ITW RAMSET/RED HEAD	IN THE CONTRACT DOCUMENTS. 6.2. ERECTION AND BRACING OF PREFABRICATED WOOD TRUSSES SHALL BE IN CONFORMANCE WITH THE RECOMMENDATIONS OF THE TRUSS MANUFACTURER AND THE TRUSS PLATE INSTITUTE'S "BRACING WOOD TRUSSES: COMMENTARY AND RECOMMENDATIONS".
<u>D</u>	 POWER-FAST EPOXY INJECTION GEL SUPPLIED BY POWERS FASTENING C. POWDER AND GAS-ACTUATED FASTENERS SHALL HAVE BEEN TESTED AND QUALIFIED FOR USE IN ACCORDANCE WITH ICC-ES AC70. PRE-APPROVED POWDER ACTUATED FASTENERS INCLUDE: 	6.3. SECURE EACH COMMON ROOF TRUSS/RAFTER TO TOP PLATE WITH SIMPSON H-10 OR H-7 HURRICANE CLIP AT ALL BEARING POINTS. USE SIMPSON H-7 AT GIRDER TRUSSES. PROVIDE A MINIMUM OF TWO STUDS UNDER GIRDER TRUSS END BEARING.
TS. (FOR CANTILEVERS, L IS TWICE	 SIMPSON STRONG-TIE "POWER-DRIVEN FASTENERS" (ICC-ES ESR-2138) SIMPSON STRONG-TIE "GAS-ACTUATED FASTENERS" (ICC-ES ESR-2811) MASONRY ANCHORS 	6.4. TRUSSES ON SITE PRIOR TO INSTALLATION SHALL BE STORED IN A VERTICAL POSITION WITH SUPPORT POINTS PROVIDED AT FINAL BEARING POINTS AND BRACED TO AVOID TIPPING.
	2.1 ANCHORAGE TO SOLID-GROUTED CONCRETE MASONRY:	 6.5. INSTALLATION OF ALL TRUSSES SHALL BE DONE USING A SPREADER BAR WITH A THREE POINT VERTICAL PICK AND CARE IS TO BE USED IN LIFTING TO MINIMIZE HORIZONTAL BENDING. 6.6. IMPROPER HANDLING OF THE TRUSSES AS NOTED ABOVE AND IN THE SPECIFICATIONS SHALL MEAN
ESSURE OF 2000 PSF. STRUCTURAL ENGINEER IE FIELD DIFFERENT FROM THOSE ASSUMED	 A. MECHANICAL ANCHORS SHALL HAVE BEEN TESTED AND QUALIFIED FOR USE IN ACCORDANCE WITH ICC-ES AC01 OR AC106. PRE-APPROVED MECHANICAL ANCHORS INCLUDE: SIMPSON STRONG-TIE "TITEN-HD" (ICC-ES ESR-1056) SIMPSON STRONG-TIE "STRONG-BOLT 2" (IAMPO-ES ER-0240) 	REMOVAL OF THE TRUSSES FROM THE JOB SITE. 6.7. TRUSS TO TRUSS CONNECTIONS SHALL BE VERIFIED BY THE TRUSS DESIGNER. 6.8. EXPOSED TRUSSES SHALL BE DELIVERED TO THE JOB SITE UNBLEMISHED AND SUITABLE FOR FIELD
PROCTOR OR 95% MODIFIED PROCTOR AS	 SIMPSON STRONG-TIE "WEDGE-ALL" (ICC-ES ESR-1396) B. ADHESIVE ANCHORS SHALL HAVE BEEN TESTED AND QUALIFIED FOR USE IN ACCORDANCE WITH ICC-ES AC58. PRE-APPROVED MECHANICAL ANCHORS INCLUDE: 	PAINTING.
RUCTED w/ 3/4" X 3/4" (MIN.) KEY WAY. ALL RETE. CONTRACTION JOINTS / SAW CUTS SHALL	- SIMPSON STRONG-TIE "AT-XP" (IAMPO-ES ER-0281) - SIMPSON STRONG-TIE "SET-XP" (IAMPO-ES ER-0265)	6.10. ALL FLOOR TRUSS DESIGN LOADS SHALL BE PER TRUSS MANUFACTURER. THE LOADS REFERENCED WITHIN THE FOLLOWING "STRUCTURAL LOADS" SECTION REPRESENTS THE LOADS USED FOR THE DESIGN OF
SLAB THICKNESS (LESSER OF THE TWO) AND HICKNESS (MIN.) UNLESS OTHERWISE NOTED. ED IN 25 SQ. FT. SECTIONS (MAXIMUM). REFER ARD OF THE COASTAL CONSTRUCTION	 HILTI HIT HY150 INJECTION ADHESIVE EPCON CERAMIC 6 EPOXY ADHESIVE SUPPLIED BY ITW RAMSET/RED HEAD POWER-FAST EPOXY INJECTION GEL SUPPLIED BY POWERS FASTENING ANCHORAGE TO HOLLOW CONCRETE MASONRY: 	STRUCTURAL MEMBERS SUPPORTING FLOOR AND ROOF TRUSSES. 7. CONNECTIONS 7.1. CONNECTIONS FOR STRUCTURAL TIMBER SHALL BE GALVANIZED STRONG TIE CONNECTORS BY THE
MEDIUM BEFORE STARTING CONSTRUCTION.	3.1 ADHESIVE ANCHORS WITH SCREEN TUBES SHALL BE TESTED AND QUALIFIED IN ACCORDANCE WITH ICC-ES AC58 OR AC60, AS APPROPRIATE. THE APPROPRIATE SCREEN TUBE SHALL BE USED AS RECOMMENDED BY THE ADHESIVE MANUFACTURER. PRE-APPROVED ADHESIVE ANCHORS WITH SCREEN	SIMPSON COMPANY OR APPROVED EQUAL. CONNECTORS SHALL FOLLOW MANUF. CORROSION PROTECTION RECOMMENDATIONS. 7.2. THE NUMBER OF FASTENERS PER CONNECTION SHALL BE THE MAX. ALLOWED FOR THAT PARTICULAR FASTENER.
ARY TO THE CONDITIONS USED FOR DESIGN OF BROUGHT TO THE ATTENTION OF THE OVERTURNING.	TUBES INCLUDE: - SIMPSON STRONG-TIE "SET" (ICC-ES ESR-1772) - SIMPSON STRONG-TIE "AT" (ICC-ES ESR-1958) - HILTI HIT HY150 INJECTION ADHESIVE - EPCON CERAMIC 6 EPOXY ADHESIVE SUPPLIED BY ITW RAMSET/RED HEAD - POWER-FAST EPOXY INJECTION GEL SUPPLIED BY POWERS FASTENING	
REQUIREMENTS FOR MASONRY STRUCTURES	4. ALL DRILLED & EPOXIED $\frac{5}{8}$ " THREADED RODS SHALL MAINTAIN A MINIMUM EDGE DISTANCE OF 1 $\frac{3}{4}$ " AND CLEAR SPACING OF 4" O.C. (MAX.)	
	CAST-IN-PLACE CONCRETE	
/I = 1,500 PSI. ONCRETE MASONRY AND SHALL BE OF THE	 ALL CONCRETE HAS BEEN DESIGNED IN ACCORDANCE WITH ACI 318 AND SHALL BE CONSTRUCTED IN ACCORDANCE WITH ACI 301. UNLESS NOTED OTHERWISE, ALL CONCRETE SHALL HAVE A 28 DAY COMPRESSIVE STRENGTH OF 3000 PSI. 	
	 ONLESS NOTED OTHERWISE, ALL CONCRETE SHALL HAVE A 28 DAT COMPRESSIVE STRENGTH OF 5000 FSI. REFER TO ARCHITECTURAL DRAWINGS FOR MOLDS, GROVES, ORNAMENTS, CLIPS OR GROUNDS REQUIRED TO BE ENCASED IN CONCRETE AND FOR LOCATION OF FLOOR FINISHES AND SLAB DEPRESSIONS. 	
DINAL WIRES AT 16" VERTICALLY, UNLESS	4. CONSTRUCTION JOINT LOCATIONS SHALL BE APPROVED BY THE STRUCTURAL ENGINEER. NO HORIZONTAL CONSTRUCTION JOINTS ARE PERMITTED EXCEPT THOSE SHOWN ON THE STRUCTURAL DRAWINGS.	
RSECTIONS, ETC. ED OTHERWISE. -COMBING, SPALLS, AND CRACKS WITH WIDTHS	5. DEFECTIVE AREAS IN CONCRETE INCLUDING, BUT NOT LIMITED TO, HONEY-COMBING, SPALLS, AND CRACKS WITH WIDTHS EXCEEDING 0.01 INCH SHALL BE REPAIRED. EXTENT OF DEFECTIVE AREA TO BE DETERMINED BY THE STRUCTURAL ENGINEER.	


RO		THE TRUSS MFG. TO NOTIFY E.O.R. OF ANY DISCREPANCY & CTURAL PLAN REVISION IF LAYOUT VARIES FROM THAT	FLOOR PORCH
1.		DR GREATER ARE INTENDED FOR 2 X 6 OR 5/4 X 6 WOOD BILITY, IF USING COMPOSITE DECKING TO INSTALL DECK	ROOF <u>SUPERIMPOSE</u>
FΤ	JCTURAL GLUED LAMINATED TIMBER SHALL BE I	ACTORERS SPECIFICATIONS. PRODUCED IN ACCORDANCE WITH THE AMERICAN INSTITUTE ABLE BENDING STRESS SHALL BE 2,400 PSI (DRY	ATTICS w/ ATTICS w/c HABITABLE
	VIDE DRESSED SEASONED LUMBER, S4S, WITH A SSING AS LISTED BELOW.	A MAXIMUM MOISTURE CONTENT OF 19% AT TIME OF	ALL OTHEF DECKS
.1.	INTERIOR AND EXTERIOR LOAD-BEARING WALL SPRUCE PINE FUR (SPF) U.N.O.	.S:	FLOOR ROOF
.2.	LINTELS, FLOOR JOISTS AND BEAMS: SOUTHERN PINE (S.P.), NO. 2 GRADE.		WIND LOADS A
.3.	USE GALVANIZED NAILS IN PRESSURE-TREATE	ONRY SHALL BE FOUNDATION GRADE PRESSURE-TREATED. D WOOD. THE PROTECTIVE COATING ON LIGHT GAUGE STEEL ATED WOOD SHALL BE IN ACCORDANCE WITH THE ATIONS.	NOMINAL STRUCTU EXPOSUF
NG	INEERED LUMBER PRODUCTS		INTERNA
.1.	PROPERTIES: ALLOWABLE BENDING STRESS COMPRESSION PERPENDICULAR TO GRAIN COMPRESSION PARALLEL TO GRAIN	THE FOLLOWING MINIMUM ALLOWABLE STRESSES AND $F_B = 2900 \text{ PSI}$ $F_{C^{\perp}} = 750 \text{ PSI}$ $F_{C } = 2900 \text{ PSI}$	
	HORIZONTAL SHEAR MODULUS OF ELASTICITY	F _V = 290 PSI E = 2,000,000 PSI	
.2.	LAMINATED VENEER LUMBER (LVL) SHALL HAVI PROPERTIES: ALLOWABLE BENDING STRESS COMPRESSION PERPENDICULAR TO GRAIN COMPRESSION PARALLEL TO GRAIN	E THE FOLLOWING MINIMUM ALLOWABLE STRESSES AND $F_B = 2600 \text{ PSI}$ $F_{C^{\perp}} = 750 \text{ PSI}$ $F_{C } = 2510 \text{ PSI}$	
	HORIZONTAL SHEAR MODULUS OF ELASTICITY	$F_V = 285 \text{ PSI}$ E = 2,000,000 PSI	
.3.	LAMINATED STRAND LUMBER (LSL) SHALL HAVI PROPERTIES: ALLOWABLE BENDING STRESS COMPRESSION PERPENDICULAR TO GRAIN	E THE FOLLOWING MINIMUM ALLOWABLE STRESSES AND $F_B = 1700 \text{ PSI}$ $F_{C^{\perp}} = 710 \text{ PSI}$ $F_{C^{\parallel}} = 1835 \text{ PSI}$ $F_{C^{\parallel}} = 100 \text{ PSI}$	
	HORIZONTAL SHEAR MODULUS OF ELASTICITY	$F_V = 425 \text{ PSI}$ E = 1,300,000 PSI	701
.4.	ALLOWABLE BENDING STRESS COMPRESSION PERPENDICULAR TO GRAIN	WING MINIMUM ALLOWABLE STRESSES AND PROPERTIES: $F_B = 3000 \text{ PSI}$ $F_{C^{\perp}} = 805 \text{ PSI}$ $F_{T } = 1350 \text{ PSI}$	ZON 4 5
	HORIZONTAL SHEAR MODULUS OF ELASTICITY	F _V = 300 PSI E = 2,100,000 PSI	***NOT
.5.	PRESERVED GLULAM BEAMS (GLU) SHALL HAV PROPERTIES: ALLOWABLE BENDING STRESS COMPRESSION PERPENDICULAR TO GRAIN	E THE FOLLOWING MINIMUM ALLOWABLE STRESSES AND $F_B = 2400 \text{ PSI}$ $F_{CL} = 740 \text{ PSI}$	

STRUCTURAL LOADS:

SUPERIMPOSED DEAD LOADS (COMMERCIA	L CONSTRUCTION)
FLOOR	20 PSF
PORCH	10 PSF
ROOF	15 PSF
SUPERIMPOSED LIVE LOADS (COMMERCIAL	CONSTRUCTION):
ATTICS w/ STORAGE	20 PSF
ATTICS w/o STORAGE	10 PSF
HABITABLE ATTICS & BEDROOMS	40 PSF
ALL OTHER ROOMS	40 PSF
DECKS	60 PSF
FLOOR	40 PSF
ROOF	20 PSF
WIND LOADS AS SPECIFIED BY ASCE 7-10 (A	ASD):
ULTIMATE WIND SPEED	140 MPH
NOMINAL WIND SPEED	108 MPH
STRUCTURAL CATEGORY	IV
EXPOSURE CATEGORY	В
INTERNAL PRESSURE COEFFICIENT	0.18 ±
IMPACT GLASS WINDOWS & DOORS	REQ'D

		MAIN W	IND FRAME	RESISTING	SYSTEM (N	/WFRS)
	AREA		IN	TERIOR ZOI	NE	
	WALLS			21.44 PSF		
	ROOF			± 18.57 PSF		
		COMPON	NENTS AND	CLADDING	ROOF PRE	SSURES
	ZONE			+ GCpi		
R	OOF (ZONE	1)		13.48		
R	OOF (ZONE	2)		13.48		
R	OOF (ZONE	3)		13.48		
		COMPON	ENTS AND (WALL PRES	SURES (
	0 SF	- 10 SF	10 SF	- 30 SF	30 SF	- 60 SF
ZONE	+ GCpi	- GCpi	+ GCpi	- GCpi	+ GCpi	- GCp
4	21.41	-25.37	21.41	-25.37	19.90	-23.70
5	21.41	-31.32	21.41	-31.32	19.90	-27.98







CERTIFICATION THE STRUCTURE SHOWN ON THESE PLANS IS DESIGNED IN ACCORDANCE CODE 6TH EDITION (2017).

ABBREVIATIONS CONC. = CONCRETE E.O.R. = ENGINEER OF RECORD WWM = WELDED WIRE MESH N.T.S. = NOT TO SCALE CONT. = CONTINUOUS BTM. = BOTTOM CMU = CONCRETE MASONRY UNIT C.I.P. = CAST IN PLACE P.T. = PRESSURE TREATED S.S. = STAINLESS STEEL N.T.S. = NOT TO SCALE TYP. = TYPICAL BTW = BETWEEN REQ'D = REQUIRED SIM = SIMILAR U.N.O. = UNLESS NOTED OTHERWISE LOC = LOCATION L.B.W. = LOAD BEARING WALL HCA = HEADED CONCRETE ANCHOR MFG. = MANUFACTURER CONT. = CONTINUOUS

	SH	EARWALL/SHEATHING NAIL SCHE	DULE (U.N.O.
	WALLS	8d	3' 6'
	ROOF	8d "RING SHANK"	3' 6'
	TONGUE	E & GROOVE SHEATHING, IF APPL	ICABLE (U.N.(
	WALLS	(2) 3" #9 DECK SREWS	EACH
	ROOF	(2) 3" #9 DECK SREWS	EACH TRU
_			

Revisions: Revisions: Revisions: Residence BY: Revisions: Revisions: Revision: Revisions: Rev						
			REVISIONS:		Υ	
Indearoner J.HUBBAND Indearoner BLOUNTSTOWN COUNTY BOARD F Indearoner J.HUBAND Indearoner J.HUBAND Indearoner BLOUNTSTOWN COUNTY BOARD F Indearoner J.HUBAND Indearoner J.HUBAND<		DESIGNED BY: DRAWN BY: CHECKED BY:	В	IRUCIURAL GENERAL NUIE)FES /LEF	ln 2 (
Image: Second of county Board of county Board of county Board of county commission BLOUNTSTOWN COUNTY BOARD of county commission Image: Second county commission Second county commission Image: Second counts commission Second counts commission Image: Second counts coun	_: вне С				SSIC R R.	
COUNTY COMMISSION COUNTY COMMISSION 20859 CENTRAL AVENUE BLOUNTSTOWN, FLORIDA 32424 BLOUNTSTOWN, FLORIDA 32424 BLOUNTSTOWN, FLORIDA 32424	E	T FOR: CALHOUN COUNTY BOARD OF			ла м <i>4</i>	SOUTHEASTERN
BLOUNTSTOWN, FLORIDA 32424 BLOUNTSTOWN, FLORIDA 32424 BLOUNTSTOWN, FLORIDA 32424	I r	COUNTY COMMISSION		BLOUNTSTOWN COURTHOUSE	L E	CONSULTING ENGINEERS, INC.
BLOUNTSTOWN, FLORIDA 32424	v/1 N□.	ZOB59 CENTRAL AVENUE EAST		ZOB59 CENTRAL AVENUE	ENGI 6H, I	P.O. BOX 141
ER 34	J			BLOUNTSTOWN, FLORIDA 32424	P.E.	WEWAHITCHKA, FL 32465 (850) 639-3860
	/					LB# 29064







E WITH FLORIDA BUILDIN	G

3" O.C. EDGE 6" O.C. FIELD 3" O.C. EDGE 6" O.C. FIELD CH STUD CONN.

RUSS/RAFTER CONN.